

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3774-0006:110

Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Sargent Mfg., 100 Sargent Drive, New Haven CT 06536
Contact: *Dan Picard (203) 498-5634 Fax (203) 498-5600

DESIGN: Special locking arrangement, Rim Type Models 59-8500, 59-8800, 12-59-8800; Surface Vertical Rod Models 59-8700, 12-59-8700; Mortise Locks Models 59-8300, 12-59-8300, 59-8900, 12-59-8900; Concealed Vertical Rod Type Models 59-8400, 12-59-MD8400, 59-WD8600, 12-59-WD8600, 59-MD8600 and 12-59-MD8600. The units are delayed exit control systems which allows exit when power loss occurs or when a fire is detected. Suffix -WD indicating wood door and -MD indicating metal door. Units are provided with a horizontal crossbar which will retract the latch or latches and open the door when the bar is depressed. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as special egress door locks for use with swinging type doors as a mean of supplemental locking of the door in addition to the door's required latching mechanism when installed in accordance with the California Building Code, Section 1003.3.1.10 Special egress-control devices. Authority having jurisdiction shall be consulted prior to installation.

*Rev. 06-19-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager